IDAHO DEPARTMENT OF
HEALTH & WELFARE

JAMES E. RISCH – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0036
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@idhw.state.id.us

August 25, 2006

FILE COPY

Dawn Hayden, Administrator
Hayden Country Guest Home - III
10565 North Reed Road
Hayden, ID 83835

License #: RC-654

Dear Ms. Hayden:

On July 12, 2006, a fire/life safety and sanitation survey was conducted at Hayden Country Guest Home - III. As a result of that survey, a deficient practice was found. The deficiency was cited at the following level:

- Non-core issue, which is described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Eric Mundell, R.E.H.S., Health Facility Surveyor, Residential Community Care Program, at (208) 334-6626.

Sincerely,

J.V. for

ERIC MUNDELL, R.E.H.S.
Team Leader
Health Facility Surveyor
Facility Fire Safety & Construction Program

EM/sm

c: Jamie Simpson, MBA, QMRP Supervisor, Residential Community Care Program

IDAHO DEPARTMENT OF
HEALTH & WELFARE

JAMES E. RISCH – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0036
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@idhw.state.id.us

July 19, 2006

Dawn Hayden, Administrator
Hayden Country Guest Home - III
10565 N Reed Rd
Hayden, ID 83835

FILE COPY

Dear Ms. Hayden:

On July 12, 2006, a fire/life safety code survey was conducted at Hayden Country Guest Home - III. The facility was found to be providing a safe environment and safe, effective care to residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying proof of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by August 11, 2006.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

JAMIE SIMPSON, BS, QRMP, MBA
Supervisor
Residential Community Care Program

JS/slc

Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R654	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - ENTIRE BUILDING B. WING	(X3) DATE SURVEY COMPLETED 07/12/2006
NAME OF PROVIDER OR SUPPLIER HAYDEN COUNTRY GUEST HOME - III	STREET ADDRESS, CITY, STATE, ZIP CODE 10565 N REED RD HAYDEN, ID 83835		

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
R9999	Initial Comments The facility was found to be in substantial compliance with the fire and life safety and sanitation standards of the Rules for Residential or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard fire/life safety and sanitation survey conducted on July12, 2006. The surveyor conducting the survey was: Eric Mundell REHS Team Leader Health Facility Surveyor	R9999		

Bureau of Facility Standards

TITLE (X6) DATE

RATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

IDAHO DEPARTMENT OF
HEALTH & WELFARE

BUREAU OF FACILITY STANDARDS
P.O. Box 83720
Boise, ID 83720-0036
(208) 334-6626 fax: (208) 364-1888

ASSISTED LIVING
Non-Core Issues
Punch List

Facility Name	Physical Address	Phone Number
Hayden County Guest Home	16549 North Reed Rd	762 9292
Administrator	**City**	**ZIP Code**
Dawn Hayden	Hayden	83835
Survey Team Leader	**Survey Type**	**Survey Date**
Eric Mandell	FLS	July 12, 2006

NON-CORE ISSUES

ITEM #	RULE #	DESCRIPTION	DATE RESOLVED
1	16.03.22.415.03	Fire Extinguishers had not been professionally serviced within a twelve month time period.	7/3/06 EM

Response Required Date	Signature of Facility Representative
~~June~~ August 12, 2006	Dawn Hayden